

CERTIFICATE OF COMPLIANCE



Draper, Inc.

Opaque Fabric for Gymnasium
Divider Curtains

Restrictions:

UL 2818 - 2013 Standard for Chemical Emissions for Building Materials, Finishes and Furnishings

Gymnasium equipment is determined compliant using ASHRAE Standard 62.1-2010 ventilation conditions with a product loading based on 8.60 m² in a gymnasium environment with a room volume of 5,750 m³.

Products tested in accordance with UL 2821 test method to show compliance to emission limits in UL 2818, Section 7.1.

4225-410

Certificate Number

10/16/2007 - 10/16/2019

Certificate Period

Certified

Status



Environment

GREENGUARD Certification Criteria for Furniture and Mattresses

Criteria	CAS Number	Maximum Allowable Predicted Concentration	Units
TVOC ^(A)	-	0.50	mg/m ³
Formaldehyde	50-00-0	61.3 (50 ppb)	µg/m ³
Total Aldehydes ^(B)	-	0.10	ppm
4-Phenylcyclohexene	4994-16-5	6.5	µg/m ³
Individual VOCs ^(C)	-	1/10th TLV	-

- (A) Defined to be the total response of measured VOCs falling within the C₆ – C₁₆ range, with responses calibrated to a toluene surrogate.
- (B) The sum of all measured normal aldehydes from formaldehyde through nonanal, plus benzaldehyde, individually calibrated to a compound specific standard. Heptanal through nonanal are measured via TD/GC/MS analysis and the remaining aldehydes are measured using HPLC/UV analysis.
- (C) Allowable levels for chemicals not listed are derived from 1/10th of the Threshold Limit Value (TLV) industrial work place standard (Reference: American Conference of Government Industrial Hygienists, 6500 Glenway, Building D-7, and Cincinnati, OH 45211-4438).



Environment