



PHIFER

INCORPORATED

31 March 2014

DRAPER INC.

Sent Via E-mail: jmiller@DraperInc.com

Re: Flame Retardance Certificate

PHIFER INCORPORATED certifies that the material described below manufactured in Tuscaloosa, Alabama, U.S.A., and furnished by our firm:

Phifer SheerWeave 3000 Vinyl Coated Polyester/Fiberglass Fabric, all colors

is in compliance with the following standard(s):

1. National Fire Protection Association, NFPA No. 101, "Life Safety Code", Class "A" rating. (Tested in accordance to ASTM E84.)
FLAME SPREAD INDEX = 20 SMOKE DEVELOPED VALUE = 250
2. International Building Code (IBC), Section 903.1, (Tested in accordance to ASTM E84), Class "A" rating.
3. NFPA 701, Standard Methods of Fire Test for Flame Propagation of Textiles and Films, 2010 Edition, (Test 1, Small Scale).
4. NFPA 701, Standard Methods of Fire Test for Flame Propagation of Textiles and Films, 2010 Edition, (Test 12 Large Scale).
5. Federal Motor Vehicles Safety Standard 302.

If you have any questions or need further information, please contact me at 1-800-633-5955 Ext. 3075.

Sincerely,
PHIFER INCORPORATED

Keith Euerle
Director of Specialty Textiles Testing and Analysis