



PHIFER INCORPORATED

31 March 2014

DRAPER INC.

Sent Via E-mail: jmiller@DraperInc.com

Re: Flame Retardance of Phifer SheerWeave 7500

PHIFER INCORPORATED certifies that the following material furnished by our firm:

SheerWeave 7500 – All colors

is in compliance with the following standard(s):

1. Flammability per California Administrative Code, Title 19, Public Safety, Section 1237, Flame Resistance Small Scale Test. (California Registration F-87601)
2. NFPA 701-2004 TM #1, Standard Methods of Fire Test for Flame Propagation of Textiles and Films, 2010 Edition (Test 1, Small Scale).
3. BS EN ISO 15025: 2002 – As cited by BS 5867-2: 2008 – British Standard Specification for fabrics for curtains, drapes and window blinds; Part 2: Type “B” Performance Requirements.
4. CAN/ULC-S109-03 Standard for Flame Tests of Flame-Resistant Fabrics & Films Small Flame Test.
5. CAN/ULC-S109-03 Standard for Flame Tests of Flame-Resistant Fabrics & Films Large Flame Test, Folded Specimens.

If you have any questions or need further information, please contact me at 1-800-633-5955 Ext. 3075.

Sincerely,

PHIFER INCORPORATED

Keith Euerle
Director, Specialty Textiles Testing and Analysis