



PHIFER
INCORPORATED

10 July 2009

DRAPER
Attn: Ryan Carmony

Sent Via Email: rcarmony@DraperInc.com

Re: Flame Retardance Certification for Phifer SheerWeave Style 2500 and 2700 Fabrics

PHIFER INCORPORATED certifies that the following material furnished by our firm:

Phifer SheerWeave 2500, 2701, 2703, 2705, and 2710 Fiberglass Vinyl Coated Fabrics are in compliance with the following standard(s): .

- 1 National Fire Protection Association, NFPA No. 101, "Life Safety Code", Class "A" rating. (Tested in accordance to ASTM E84.)
FLAME SPREAD INDEX = 15 SMOKE DEVELOPED VALUE = 80.
2. Uniform Building Code, 1979 Edition, Part VIII, "Fire Resistive Standard for Fire Protection", Chapter 42 – Interior Wall and Ceiling Finish, Sections 4201-4205, Class I. (Tested in accordance to ASTM E84.)
3. NFPA 701-2004 TM #1, Standard Methods of Fire Test for Flame Resistant Textiles and Films 2004 Edition – Test Method #1 (Small Scale).
4. NFPA 701-2004 TM#2, Flame Resistant Textiles and Films, 2004 Edition, Test 2, Large Scale – Single Flat Specimen.
5. British Standard 5867: Part 2: 2008 Type B Performance Requirements.
6. Flammability per California Administrative Code, Title 19, Public Safety, Subchapter 8, Article 4, Sections 1272 (C) and referenced Article 4, Section 1237, Paragraph (b), Small Scale.
7. CAN/ULC-S109-M87 Standard for Flame Tests of flame-Resistant Fabrics & Films Small Flame Test.
8. CAN/ULC-S109-M87 Standard for Flame Tests of flame-Resistant Fabrics & Films Large Flame Test.

If you have any questions or need further information, please contact me at 1-800-633-5955, ext 4754.

Sincerely,
PHIFER INCORPORATED

Johnny Skinner
Quality Control Manager