

CERTIFICATE OF COMPLIANCE



Phifer, Inc.

SheerWeave[®] Style 2701 -
Average openness 1⁰%

Restrictions:

UL 2818 - 2013 Standard for Chemical Emissions for Building Materials, Finishes and Furnishings

4920-410

Certificate Number

07/19/2006 - 07/19/2019

Certificate Period

Certified

Status

Window treatments are determined compliant in accordance with an Office environment with an air change of 0.68 hr^{-1} and a loading of 1.49 m^2 .

Products tested in accordance with UL 2821 test method to show compliance to emission limits in UL 2818, Section 7.1.



Environment

GREENGUARD Certification Criteria for Building Products and Interior Finishes

| Criteria | CAS Number | Maximum Allowable Predicted Concentration | Units |
|--|------------|---|-------------------|
| TVOC ^(A) | - | 0.50 | mg/m ³ |
| Formaldehyde | 50-00-0 | 61.3 (50 ppb) | µg/m ³ |
| Total Aldehydes ^(B) | - | 0.10 | ppm |
| Particle Matter less than 10 µm ^(C) | - | 50 | µg/m ³ |
| 4-Phenylcyclohexene | 4994-16-5 | 6.5 | µg/m ³ |
| Individual VOCs ^(D) | - | 1/10th TLV | - |

- (A) Defined to be the total response of measured VOCs falling within the C₆ – C₁₆ range, with responses calibrated to a toluene surrogate. Maximum allowable predicted TVOC concentrations for GREENGUARD (0.50 mg/m³) fall in the range of 0.5 mg/m³ or less, as specified in CDPH Standard Method v1.1.
- (B) The sum of all measured normal aldehydes from formaldehyde through nonanal, plus benzaldehyde, individually calibrated to a compound specific standard. Heptanal through nonanal are measured via TD/GC/MS analysis and the remaining aldehydes are measured using HPLC/UV analysis.
- (C) Particle emission requirement only applicable to HVAC Duct Products with exposed surface area in air streams (a forced air test with specific test method) and for wood finishing (sanding) systems.
- (D) Allowable levels for chemicals not listed are derived from 1/10th of the Threshold Limit Value (TLV) industrial work place standard (Reference: American Conference of Government Industrial Hygienists, 6500 Glenway, Building D-7, and Cincinnati, OH 45211-4438).



Environment