



PHIFER

INCORPORATED

30 March 2022

Re: SheerWeave Basic 1%

PHIFER INCORPORATED (Tuscaloosa, Alabama) certifies that the material referenced above complies with the standards listed below:

1. Flammability per California Administrative Code, Title 19, Public Safety, Section 1237.1, Flame Resistance, Small Scale Test.
2. National Fire Protection Association, NFPA No. 101, "Life Safety Code", Class "A" rating. (Tested in accordance to ASTM E84-21a.)
3% - FLAME SPREAD INDEX = 15 SMOKE DEVELOPED VALUE = 200
3. International Building Code (IBC), Section 803.1.1, (Tested in accordance to ASTM E84-21a), Class "A" rating.
4. NFPA 701-2019, TM #1, Standard Methods of Fire Test for Flame Resistant Textiles and Films Test Method #1 (Small Scale).
5. NFPA 701-2019, TM#2, Standard Methods of Fire Tests for Flame Resistant Textiles and Films Test Method #2 (Flat Sheet Specimens).
6. CAN/ULC-S109-14 Standard for Flame Tests of flame-Resistant Fabrics & Films Small Flame Test.
7. CAN/ULC-S109-14 Standard for Flame Tests of flame-Resistant Fabrics & Films Large Flame Test.
8. CAN/CGSB2-4.162-M80 as specified by Canadian General Standards Board, National Standard of Canada, CAN2-4.162-M80 "Hospital Textiles - Flammability Performance Requirements".
9. BS EN ISO 15025:2016 - protection against heat and flame - Method of test for limited flame spread (Procedure A - Surface Ignition); as cited by BS 5867:2008 - British Standard Specification for Fabrics for curtains, drapes and window blinds; Part 2: Type "B" Performance Requirements.

If you have any questions or need further information, please contact me at 205-345-2120.

Sincerely,
PHIFER INCORPORATED

Keith Euerle
Director, Specialty Textiles Testing and Analysis

*Testing was performed by a 3rd party certified laboratory on samples representing products listed.